



cfo@suratmunicipal.org



FORM B 13.3
FIRE SAFETY CERTIFICATE RENEWAL (FSCR)
(See Rule 25)

Fire Safety Certificate Approval (FSCA) No. FSCA/O/CFOSMC/2023/00030606

Date: 02/02/2026

FSC Safety Certificate Renewal (FSCR) No. FSCA/O/CFOSMC/2023/00030606/R1

Building Occupancy/Category: Educational (non-residential)

To,

DHARMENDRA KASHYAP

SCJ TAPOVAN JAIN SCHOOL SURAT MANAGED BY SHREE DHANNA SHALIBHADRA TRUST SCJ TAPOVAN JAIN SCHOOL,
OPP. CELLENIO WALKER'S SHOPPERS, PALANPOR- CANAL ROAD, SURAT-395009 SURAT Surat MC 395009

Fire Region: Surat MC

Mobile No: 9724103099 Email ID: aartienterprise099@gmail.com

We have received Application No. **2026/00169367** dated 21/01/2026 for **Fire Safety Certificate Renewal (FSCR)** - New Building(FSCR)/Existing Building (FSCRe) for the building/premise **SCJ TAPOVAN JAIN SCHOOL SURAT MANAGED BY SHREE DHANNA SHALIBHADRA TRUST (name of the Building/ Project)**, as per below mentioned details:

1. TP Number: 9
2. FP Number:
3. Survey Number:
4. Village Name: SURAT
5. Name of Block(s): SCJ TAPOVAN JAIN SCHOOL SURAT MANAGED BY SHREE DHANNA SHALIBHADRA TRUST

The building/premise was inspected on **02/02/2026** and all fire prevention, life safety and fire protection measures provided were found to be in proper and effective working condition. There are no changes in building/premise use or occupancy or in building design or structure.

Further, the following activities (as applicable) have been carried out towards meeting requirements of GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 as amended, or the then applicable GDCR:

1. Emergency drill was carried out on **02/02/2026**
2. Six monthly inspection was done on **02/02/2026**

The Fire Safety Certificate is renewed for a period of **two (2)** years upto **02/02/2028** in accordance with GFP&LSM Act-2013, GFP&LSM Rules-2014 & GFP&LSM Regulations-2023 and their amendments.

This is issued based on the verification and approval of the RFO/CFO dated: **27/01/2026 1:31:14 PM**



Digitally Verified

Digitally verified by: Girishkumar Bhavanishankar Upadhyay
Fire Safety Officer - Specialist (FSO-S)
2021/001568
Reviewed by : CFO Surat MC
Date: 02/02/2026
Time: 02:45 PM



FSCA/O/CFOSMC/2023/00030606/R1

This is a digitally verified certificate, hence doesn't require physical signature. To validate authenticity of this certificate, scan the QR code or search the certificate details in appropriate section at www.gujfiresafetycop.in.

Please note that, apart from renewal, the building needs to be inspected every six months and a mock fire and emergency drill also needs to be conducted every six months. If there is a delay in scheduled inspection or mock drill, penalty shall be imposed. The Fire Safety Certificate renewal should be done timely after two years to avoid penalties.